

# EMx™ Multi-Pollutant Control Technology



## EmeraChem Power™

Jeff Valmus  
Vice President and General Manager

August 3, 2009  
Pasadena Convention Center



# EMx Establishes New Basis For BACT



- ▶ All criteria pollutants
  - NO<sub>x</sub>
  - CO
  - NH<sub>3</sub>
  - Formaldehyde
  - Benzene
  - VOCs
  - Sulfur
- ▶ Operating performance is a matter of public record but has not yet reset the BACT standards

# Gas Turbine Application




- ▶ Redding Electric Utility, Unit 5
  - 45 MW Alstom GTX-100 gas turbine

| Year | Average ppm NOx dry @ 15 % O2 |
|------|-------------------------------|
| 2002 | <b>0.93</b>                   |
| 2003 | <b>1.06</b>                   |
| 2004 | <b>1.04</b>                   |
| 2005 | <b>0.67</b>                   |
| 2006 | <b>0.54</b>                   |
| 2007 | <b>0.76</b>                   |
| 2008 | <b>0.62</b>                   |

*In every year of operation Redding Unit 5 has been the cleanest GT EGF in the State of California‡*

‡source: U.S. EPA



# Comparison of EmeraChem Power SCR and EMx




|   | SCR                       | EMx™  |
|---|---------------------------|---|
| Additional catalyst system required for CO and VOC reduction? | yes; SCR reduces NOx only | no; EMx™ is a multi-pollutant catalyst                    |
| NOx emission @15–25 ppm NOx inlet                             | 1.5 – 2.5 ppm             | 0.4 – 1.5 ppm   |
| NH3 slip @15–25 ppm NOx inlet                                 | 5 – 10 ppm                | 0   |
| NOx emission @ <10 ppm NOx inlet                              | 2 – 5 ppm                 | 0.2 – 1.0 ppm   |
| NH3 slip @ <10 ppm NOx inlet                                  | 2 – 10 ppm                | 0   |
| Additional catalyst required when NOx inlet <10 ppm?          | yes                       | No  |
| Fine Particulate (PM–10)                                      | SCR generates PM–10       | EMx™ reduces PM–10  |
| Disposition of spent catalyst                                 | hazardous; solid waste    | non-hazardous; recovery value for platinum precious metal |

# EMx Performance & Operational Status



| Installation                                 | On-Line Date    | GT Power, MW  | Operational Hours | Operating Temp (F) | Reduction % Guaranteed/Expected | Average NOx Out (ppm) |
|--|-----------------|---------------|-------------------|--------------------|---------------------------------|-----------------------|
| Wyeth Biopharma Unit 2<br>Solar Taurus 60    | 9/1/03          | 5.5           | 37,167            | 625                | 90/>95                          | <0.5 gas<br><2.0 oil  |
| Montefiore Medical Center<br>Solar Taurus 60 | 6/1/02          | 5.5           | 47,684            | 525                | 90/>95                          | <0.7                  |
| Redding Electric Unit 5<br>Alstom GTX 100    | 6/1/02          | 45            | 41,084            | 525                | 95/>95                          | <0.5                  |
| UCSD Cogen Facility<br>2x Solar Titan 130    | 7/1/01          | 2x15          | 110,788           | 420                | 90/>95                          | <1.0                  |
| Wyeth Biopharma Unit 1<br>Solar Taurus 60    | 1/1/99          | 5.5           | 76,382            | 650                | 90/>95                          | <1.5 gas<br><10.0 oil |
| Sunlaw Federal<br>GE LM2500                  | 1996<br>(decom) | 32            | 25,000            | 310                | 95/>95                          | <1.0                  |
| Sunlaw Growers<br>GE LM2500                  | 1996<br>(decom) | 32            | 16,000            | 310                | 95/>95                          | <1.0                  |
| <b>Total Installed Capacity</b>              |                 | <b>156 MW</b> | <b>370,106</b>    |                    |                                 |                       |

# Net Emission Reduction of Criteria Pollutants EMx vs. SCR for a 7FA Combined Cycle



|  | Removal Efficiencies |      | Annual Emissions Controlled (TPY) |     | Annual Guaranteed Emissions Reduction with EMx (TPY) | 10 Year Guaranteed Emissions Reduction with EMx (tons) |
|--|----------------------|------|-----------------------------------|-----|--|--|
|  | EMx                  | SCR  | EMx                               | SCR |  |  |
| NOx  | 94%                  | 90%  | 187                               | 178 | 8.9  | 89.2   |
| CO   | 99%                  | 90%  | 119                               | 108 | 11.1   | 110.7  |
| VOC  | 90%                  | 50%  | 8.6                               | 5.3 | 3.3  | 33   |
| SO <sub>2</sub>                            | 97%                  | 0    | 4.5                               | 0.0 | 4.5  | 45   |
| NH <sub>3</sub>                            | n/a                  | slip | 39.1                              | 0.0 | 39.1   | 391  |
| PM-10                                      | 30%                  | 0    | 82.6                              | 0.0 | 82.6   | 826  |
| <b><u>Emission Reduction with EM x</u></b> |                      |      |                                   |     | 149.5  | 1495   |

# Cost Effectiveness



- ▶ Capital Recovery Analysis
  - 10 % interest rate
  - 15 year annuity
  - Fixed current dollars

|  | <b>Cost Effectiveness</b> |              |               |               |
|--|---------------------------|--------------|---------------|---------------|
|  | <b>LM6000</b>             |              | <b>GE 7FA</b> |               |
|  | <b>SCR</b>                | <b>EMx</b>   | <b>SCR</b>    | <b>EMx</b>    |
| Total Capital Investment                 | \$ 4,104,730              | \$ 7,256,357 | \$ 12,687,346 | \$ 15,651,488 |
| Annual Operating Cost                    | \$ 1,663,190              | \$ 2,094,840 | \$ 4,961,113  | \$ 5,260,678  |
| Levelized Cost of Control,<br>\$/ton-NOx | 20,952                    | 22,694       | 27,854        | 27,996        |

*Total Capital Investment costs include the system equipment, catalyst, engineering and installation, commissioning and start-up and shipping charges*

# Implications – Advanced Technology Enables Advanced Clean Air Policy



- ▶ Ultra-clean technology supports CAA attainment objectives
- ▶ BACT analysis for discrete pollutants can give way to a *combined BACT* analysis for multi-pollutants
  - Regulatory advantages
  - Business/economic advantages
- ▶ Consider ultra fast-track permitting for power plant applications with advanced technology for ultra-low emissions

# Implications – Advanced Technology Enables Advanced Clean Air Policy



- ▶ “Optimal plant” is a combined cycle configuration with ultra-clean EMx technology
  - Supports objectives of AB32 by reducing CO<sub>2</sub> by 33% per MW generated
  - Supports reductions of all criteria pollutants
- ▶ Enables new capacity to be permitted therefore satisfying California’s growing power demands